

3) 室内ユニット運転台数による能力変化

同時運転時の各室内ユニット冷・暖房能力は下表の通りです。

冷房

運転台数	室内ユニット(形番)				容量(形番) 合計	冷房能力 kW			
	J22	J28	J32	J40					
1台運転	□				J22	2.20			
		△			J28	2.80			
			○		J32	3.20			
				◇	J40	4.00			
2台運転	□□				J44	2.20	2.20		
	□□	△			J50	2.20	2.80		
	□□		○		J54	2.20	3.20		
	□□			◇	J62	2.20	4.00		
		△△			J56	2.80	2.80		
		△	○		J60	2.80	3.20		
		△		◇	J68	2.80	4.00		
			○○		J64	3.20	3.20		
			○	◇	J72	3.13	3.91		
				◇◇	J80	3.60	3.60		
3台運転	□□□				J66	2.20	2.20	2.20	
	□□□	△			J72	2.15	2.15	2.74	
	□□□		○		J76	2.06	2.06	3.00	
	□□□			◇	J84	1.91	1.91	3.47	
	□□□	△△			J78	2.02	2.57	2.57	
	□□□	△	○		J82	1.94	2.47	2.83	
	□□□	△		◇	J90	1.81	2.30	3.29	
	□□□		○○		J86	1.87	2.72	2.72	
	□□□		○	◇	J94	1.75	2.55	3.18	
	□□□			◇◇	J102	1.65	3.00	3.00	
		△△△			J84	2.43	2.43	2.43	
		△△	○		J88	2.34	2.34	2.68	
		△△		◇	J96	2.19	2.19	3.13	
		△	○○		J92	2.26	2.59	2.59	
		△	○	◇	J100	2.13	2.43	3.04	
		△		◇◇	J108	2.01	2.87	2.87	
			○○○		J96	2.51	2.51	2.51	
			○○○	◇	J104	2.36	2.36	2.95	
			○	◇◇	J112	2.24	2.80	2.80	
				◇◇◇	J120	2.67	2.67	2.67	
4台運転	□□□□				J88	1.84	1.84	1.84	1.84
	□□□□	△			J94	1.75	1.75	1.75	2.23
	□□□□		○		J98	1.70	1.70	1.70	2.47
	□□□□			◇	J106	1.60	1.60	1.60	2.91
	□□□□	△△			J100	1.67	1.67	2.13	2.13
	□□□□	△	○		J104	1.62	1.62	2.07	2.36
	□□□□	△		◇	J112	1.54	1.54	1.96	2.80
	□□□□		○○		J108	1.58	1.58	2.30	2.30
	□□□□		○	◇	J116	1.50	1.50	2.18	2.73
	□□□□	△△△			J106	1.60	2.04	2.04	2.04
	□□□□	△△	○		J110	1.56	1.99	1.99	2.27
	□□□□	△△		◇	J118	1.48	1.89	1.89	2.70
	□□□□	△	○○		J114	1.52	1.94	2.21	2.21
	□□□□		○○○		J118	1.48	2.16	2.16	2.16
		△△△△			J112	1.96	1.96	1.96	1.96
		△△△	○		J116	1.91	1.91	1.91	2.18
		△△	○○		J120	1.87	1.87	2.13	2.13

5.製品データ

2 冷房・暖房能力

暖房

[illegible]

2

冷房・暖房能力

暖房

運転台数	室内ユニット(形番)				容量(形番) 合計	暖房能力 kW				
	J22	J28	J32	J40						
4台運転 (続き)		△△	○	◇	J128	2.22	2.22	2.47	3.09	
		△△		◇◇	J136	2.09	2.09	2.91	2.91	
		△	○○○		J124	2.31	2.56	2.56	2.56	
		△	○○	◇	J132	2.17	2.41	2.41	3.01	
		△	○	◇◇	J140	2.05	2.27	2.84	2.84	
			○○○○○		J128	2.50	2.50	2.50	2.50	
			○○○	◇	J136	2.35	2.35	2.35	2.94	
5台運転	□□□□□				J110	1.98	1.98	1.98	1.98	1.98
	□□□□□	△			J116	1.89	1.89	1.89	1.89	2.43
	□□□□□		○		J120	1.84	1.84	1.84	1.84	2.63
	□□□□□			◇	J128	1.73	1.73	1.73	1.73	3.09
	□□□□	△△			J122	1.79	1.79	1.79	2.31	2.31
	□□□□	△	○		J126	1.75	1.75	1.75	2.25	2.50
	□□□□	△		◇	J134	1.65	1.65	1.65	2.12	2.94
	□□□□		○○		J130	1.71	1.71	1.71	2.44	2.44
	□□□□		○	◇	J138	1.61	1.61	1.61	2.30	2.87
	□□□	△△△			J128	1.71	1.71	2.20	2.20	2.20
	□□□	△△	○		J132	1.67	1.67	2.14	2.14	2.38
	□□□	△△		◇	J140	1.57	1.57	2.02	2.02	2.81
	□□	△	○○		J136	1.63	1.63	2.09	2.33	2.33
	□	△△△△			J134	1.63	2.09	2.09	2.09	2.09
	□	△△△	○		J138	1.59	2.05	2.05	2.05	2.27
		△△△△△			J140	2.00	2.00	2.00	2.00	2.00