

4. 冷房・暖房能力特性

1) YCJ80 (3P) 標準能力表

運転条件：JIS B 8616条件

台数	室内ユニット容量	合計能力		ガス消費量m³N/h							
				13A		12A		LPG		L1 (6B・6C)	
		冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房
1台	J90	8.0	9.5	0.86	0.86	0.94	0.94	0.39	0.39	1.89	1.89

2) YCSP112 (4P) 標準能力表

運転条件：JIS B 8616条件

台数	室内ユニット容量	合計能力		ガス消費量 m³N/h					
				13A		12A		LPG	
		冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房
1台	P112	11.2	14.0	0.94	0.94	1.03	1.03	0.43	0.43

製品仕様

3) YCSJ140MX (5Pマルチ) 標準能力表

運転条件：JIS B 8616条件

室内 ユニット 容量 合計	合計能力 kW		ガス消費量(m³N/h)															
			13A		12A		LPG		ブタン		6A		L1 (6B, 6C)		L2 (5A, 5B) 5C, L1 (7C)		L3 (4A, 4B, 4C)	
	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房
J182	14.9	18.4	1.63	1.59	1.79	1.75	0.75	0.73	0.60	0.59	2.55	2.50	3.58	3.50	3.97	3.89	4.97	4.87
J181	14.9	18.4	1.62	1.60	1.79	1.76	0.75	0.73	0.60	0.59	2.55	2.51	3.57	3.51	3.96	3.90	4.97	4.89
J180	14.9	18.4	1.62	1.60	1.78	1.76	0.75	0.74	0.60	0.59	2.55	2.51	3.57	3.52	3.96	3.90	4.96	4.90
J179	14.8	18.4	1.62	1.60	1.78	1.76	0.75	0.74	0.60	0.59	2.54	2.52	3.56	3.53	3.95	3.91	4.96	4.91
J178	14.8	18.4	1.62	1.61	1.78	1.77	0.74	0.74	0.60	0.59	2.54	2.52	3.56	3.54	3.95	3.92	4.95	4.92
J177	14.8	18.4	1.62	1.61	1.78	1.77	0.74	0.74	0.60	0.60	2.54	2.53	3.56	3.54	3.94	3.93	4.95	4.93
J176	14.8	18.3	1.61	1.61	1.78	1.78	0.74	0.74	0.60	0.60	2.53	2.53	3.55	3.55	3.94	3.94	4.94	4.94
J175	14.8	18.3	1.61	1.62	1.77	1.78	0.74	0.74	0.60	0.60	2.53	2.54	3.55	3.56	3.93	3.95	4.93	4.95
J174	14.7	18.3	1.61	1.62	1.77	1.78	0.74	0.75	0.60	0.60	2.53	2.55	3.54	3.57	3.93	3.96	4.93	4.96
J173	14.7	18.3	1.61	1.63	1.77	1.79	0.74	0.75	0.60	0.60	2.53	2.55	3.54	3.58	3.93	3.97	4.92	4.97
J172	14.7	18.3	1.61	1.63	1.77	1.79	0.74	0.75	0.59	0.60	2.52	2.56	3.54	3.58	3.92	3.97	4.92	4.98
J171	14.7	18.3	1.61	1.63	1.77	1.80	0.74	0.75	0.59	0.60	2.52	2.56	3.53	3.59	3.92	3.98	4.91	4.99
J170	14.6	18.3	1.60	1.64	1.76	1.80	0.74	0.75	0.59	0.61	2.52	2.57	3.53	3.60	3.91	3.99	4.91	5.01
J169	14.6	18.3	1.60	1.64	1.76	1.80	0.74	0.75	0.59	0.61	2.51	2.57	3.52	3.61	3.91	4.00	4.90	5.02
J168	14.6	18.3	1.60	1.64	1.76	1.81	0.74	0.76	0.59	0.61	2.51	2.58	3.52	3.61	3.90	4.01	4.90	5.03
J167	14.6	18.3	1.60	1.65	1.76	1.81	0.74	0.76	0.59	0.61	2.51	2.58	3.52	3.62	3.90	4.02	4.89	5.04
J166	14.6	18.2	1.60	1.65	1.76	1.82	0.73	0.76	0.59	0.61	2.51	2.59	3.51	3.63	3.90	4.03	4.89	5.05
J165	14.5	18.2	1.59	1.65	1.75	1.82	0.73	0.76	0.59	0.61	2.50	2.60	3.51	3.64	3.89	4.03	4.88	5.06
J164	14.5	18.2	1.59	1.66	1.75	1.82	0.73	0.76	0.59	0.61	2.50	2.60	3.50	3.65	3.89	4.04	4.87	5.07
J163	14.5	18.2	1.59	1.66	1.75	1.83	0.73	0.76	0.59	0.61	2.50	2.61	3.50	3.65	3.88	4.05	4.87	5.08
J162	14.5	18.2	1.59	1.66	1.75	1.83	0.73	0.77	0.59	0.62	2.50	2.61	3.50	3.66	3.88	4.06	4.86	5.09
J161	14.5	18.2	1.59	1.67	1.75	1.83	0.73	0.77	0.59	0.62	2.49	2.62	3.49	3.67	3.87	4.07	4.86	5.10
J160	14.4	18.2	1.59	1.67	1.74	1.84	0.73	0.77	0.59	0.62	2.49	2.62	3.49	3.68	3.87	4.08	4.85	5.11
J159	14.4	18.2	1.58	1.68	1.74	1.84	0.73	0.77	0.59	0.62	2.49	2.63	3.48	3.69	3.86	4.09	4.85	5.13
J158	14.4	18.2	1.58	1.68	1.74	1.85	0.73	0.77	0.59	0.62	2.48	2.64	3.48	3.69	3.86	4.10	4.84	5.14
J157	14.4	18.2	1.58	1.68	1.74	1.85	0.73	0.77	0.58	0.62	2.48	2.64	3.48	3.70	3.86	4.10	4.84	5.15
J156	14.3	18.2	1.58	1.69	1.74	1.85	0.73	0.78	0.58	0.62	2.48	2.65	3.47	3.71	3.85	4.11	4.83	5.16
J155	14.3	18.1	1.58	1.69	1.73	1.86	0.73	0.78	0.58	0.63	2.48	2.65	3.47	3.72	3.85	4.12	4.82	5.17
J154	14.3	18.1	1.58	1.69	1.73	1.86	0.72	0.78	0.58	0.63	2.47	2.66	3.47	3.72	3.84	4.13	4.82	5.18
J153	14.3	18.1	1.57	1.70	1.73	1.87	0.72	0.78	0.58	0.63	2.47	2.66	3.46	3.73	3.84	4.14	4.81	5.19
J152	14.3	18.1	1.57	1.70	1.73	1.87	0.72	0.78	0.58	0.63	2.47	2.67	3.46	3.74	3.83	4.15	4.81	5.20
J151	14.2	18.1	1.57	1.70	1.73	1.87	0.72	0.78	0.58	0.63	2.46	2.67	3.45	3.74	3.83	4.15	4.80	5.20
J150	14.2	18.1	1.57	1.70	1.72	1.87	0.72	0.78	0.58	0.63	2.46	2.67	3.45	3.73	3.82	4.14	4.80	5.20
J149	14.2	18.1	1.57	1.70	1.72	1.87	0.72	0.78	0.58	0.63	2.46	2.67	3.45	3.73	3.82	4.14	4.79	5.19
J148	14.2	18.1	1.56	1.70	1.72	1.87	0.72	0.78	0.58	0.63	2.46	2.66	3.44	3.73	3.82	4.14	4.79	5.19
J147	14.2	18.1	1.56	1.70	1.72	1.87	0.72	0.78	0.58	0.63	2.45	2.66	3.44	3.73	3.81	4.14	4.78	5.19
J146	14.1	18.1	1.56	1.70	1.72	1.86	0.72	0.78	0.58	0.63	2.45	2.66	3.43	3.73	3.81	4.14	4.78	5.19
J145	14.1	18.0	1.56	1.69	1.71	1.86	0.72	0.78	0.58	0.63	2.45	2.66	3.43	3.73	3.80	4.13	4.77	5.18
J144	14.1	18.0	1.56	1.69	1.71	1.86	0.72	0.78	0.58	0.63	2.44	2.66	3.43	3.73	3.80	4.13	4.76	5.18
J143	14.1	18.0	1.56	1.69	1.71	1.86	0.72	0.78	0.58	0.63	2.44	2.66	3.42	3.72	3.80	4.13	4.76	5.18
J142	14.0	18.0	1.55	1.69	1.71	1.86	0.71	0.78	0.57	0.63	2.44	2.66	3.42	3.72	3.79	4.13	4.75	5.18
J140	14.0	18.0	1.55	1.69	1.71	1.86	0.71	0.78	0.57	0.63	2.43	2.65	3.41	3.72	3.78	4.12	4.74	5.17
J139	13.9	17.9	1.54	1.68	1.69	1.85	0.71	0.77	0.57	0.62	2.42	2.63	3.38	3.69	3.75	4.09	4.71	5.13
J138	13.8	17.7	1.53	1.67	1.68	1.83	0.70	0.77	0.57	0.62	2.40	2.62	3.36	3.66	3.73	4.06	4.67	5.10
J137	13.7	17.6	1.52	1.65	1.67	1.82	0.70	0.76	0.56	0.61	2.38	2.60	3.33	3.64	3.70	4.03	4.64	5.06
J136	13.6	17.5	1.50	1.64	1.65	1.81	0.69	0.76	0.56	0.61	2.36	2.58	3.31	3.61	3.67	4.01	4.60	5.02
J135	13.5	17.4	1.49	1.63	1.64	1.79	0.69	0.75	0.55	0.60	2.34	2.56	3.28	3.58	3.64	3.98	4.57	4.99

室内 ユニット 容量 合計	合計能力 kW		ガス消費量(m ³ N/h)															
			13A		12A		LPG		ボタン		6A		L1 (6B, 6C)		L2 (5A, 5B) 5C, L1 (7C)		L3 (4A, 4B, 4C)	
	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房
J134	13.4	17.2	1.48	1.62	1.63	1.78	0.68	0.74	0.55	0.60	2.33	2.54	3.26	3.56	3.62	3.95	4.53	4.95
J133	13.3	17.1	1.47	1.61	1.62	1.77	0.68	0.74	0.54	0.59	2.31	2.52	3.23	3.53	3.59	3.92	4.50	4.91
J132	13.2	17.0	1.46	1.59	1.60	1.75	0.67	0.73	0.54	0.59	2.29	2.50	3.21	3.50	3.56	3.89	4.46	4.87
J131	13.1	16.8	1.45	1.58	1.59	1.74	0.67	0.73	0.54	0.58	2.27	2.48	3.18	3.48	3.53	3.86	4.43	4.84
J130	13.0	16.7	1.44	1.57	1.58	1.73	0.66	0.72	0.53	0.58	2.25	2.46	3.16	3.45	3.50	3.83	4.39	4.80
J129	12.9	16.6	1.42	1.56	1.57	1.71	0.66	0.72	0.53	0.58	2.24	2.44	3.13	3.42	3.48	3.80	4.36	4.76
J128	12.8	16.5	1.41	1.54	1.55	1.70	0.65	0.71	0.52	0.57	2.22	2.42	3.11	3.40	3.45	3.77	4.32	4.73
J127	12.7	16.3	1.40	1.53	1.54	1.69	0.64	0.70	0.52	0.57	2.20	2.41	3.08	3.37	3.42	3.74	4.29	4.69
J126	12.6	16.2	1.39	1.52	1.53	1.67	0.64	0.70	0.51	0.56	2.18	2.39	3.06	3.34	3.39	3.71	4.25	4.65
J125	12.5	16.1	1.38	1.51	1.52	1.66	0.63	0.69	0.51	0.56	2.17	2.37	3.03	3.32	3.36	3.68	4.22	4.61
J124	12.4	15.9	1.37	1.50	1.50	1.65	0.63	0.69	0.51	0.55	2.15	2.35	3.01	3.29	3.34	3.65	4.18	4.58
J123	12.3	15.8	1.36	1.48	1.49	1.63	0.62	0.68	0.50	0.55	2.13	2.33	2.98	3.26	3.31	3.62	4.15	4.54
J122	12.2	15.7	1.34	1.47	1.48	1.62	0.62	0.68	0.50	0.54	2.11	2.31	2.96	3.24	3.28	3.59	4.12	4.50
J121	12.1	15.6	1.33	1.46	1.47	1.61	0.61	0.67	0.49	0.54	2.09	2.29	2.93	3.21	3.25	3.56	4.08	4.47
J120	12.0	15.4	1.32	1.45	1.45	1.59	0.61	0.67	0.49	0.54	2.08	2.27	2.91	3.18	3.23	3.53	4.05	4.43
J118	11.8	15.2	1.30	1.42	1.43	1.57	0.60	0.65	0.48	0.53	2.04	2.23	2.86	3.13	3.17	3.47	3.98	4.35
J117	11.7	15.0	1.29	1.41	1.42	1.55	0.59	0.65	0.48	0.52	2.02	2.21	2.83	3.10	3.14	3.44	3.94	4.32
J116	11.6	14.9	1.28	1.40	1.40	1.54	0.59	0.64	0.47	0.52	2.00	2.20	2.81	3.08	3.11	3.41	3.91	4.28
J115	11.5	14.8	1.27	1.39	1.39	1.53	0.58	0.64	0.47	0.51	1.99	2.18	2.78	3.05	3.09	3.38	3.87	4.24
J114	11.4	14.7	1.25	1.37	1.38	1.51	0.58	0.63	0.46	0.51	1.97	2.16	2.76	3.02	3.06	3.35	3.84	4.21
J112	11.2	14.4	1.23	1.35	1.35	1.49	0.57	0.62	0.46	0.50	1.93	2.12	2.71	2.97	3.00	3.29	3.77	4.13
J111	11.1	14.3	1.22	1.34	1.34	1.47	0.56	0.62	0.45	0.50	1.91	2.10	2.68	2.94	2.98	3.26	3.73	4.09
J110	11.0	14.1	1.21	1.33	1.33	1.46	0.56	0.61	0.45	0.49	1.90	2.08	2.66	2.92	2.95	3.23	3.70	4.06
J109	10.9	14.0	1.20	1.31	1.32	1.44	0.55	0.60	0.44	0.49	1.88	2.06	2.63	2.89	2.92	3.21	3.66	4.02
J108	10.8	13.9	1.19	1.30	1.30	1.43	0.55	0.60	0.44	0.48	1.86	2.04	2.61	2.86	2.89	3.18	3.63	3.98
J107	10.7	13.8	1.17	1.29	1.29	1.42	0.54	0.59	0.43	0.48	1.84	2.02	2.58	2.84	2.86	3.15	3.59	3.95
J106	10.6	13.6	1.16	1.28	1.28	1.40	0.53	0.59	0.43	0.47	1.82	2.01	2.56	2.81	2.84	3.12	3.56	3.91
J103	10.3	13.2	1.13	1.24	1.24	1.36	0.52	0.57	0.42	0.46	1.77	1.95	2.48	2.73	2.75	3.03	3.45	3.80
J102	10.2	13.1	1.12	1.23	1.23	1.35	0.51	0.57	0.41	0.45	1.75	1.93	2.46	2.70	2.72	3.00	3.42	3.76
J101	10.1	13.0	1.11	1.22	1.22	1.34	0.51	0.56	0.41	0.45	1.74	1.91	2.43	2.68	2.70	2.97	3.38	3.72
J100	10.0	12.9	1.09	1.20	1.20	1.32	0.50	0.55	0.40	0.45	1.72	1.89	2.41	2.65	2.67	2.94	3.35	3.69
J99	9.9	12.7	1.08	1.19	1.19	1.31	0.50	0.55	0.40	0.44	1.70	1.87	2.38	2.62	2.64	2.91	3.31	3.65
J95	9.5	12.2	1.04	1.14	1.14	1.26	0.48	0.53	0.38	0.42	1.63	1.80	2.28	2.52	2.53	2.79	3.17	3.50
J94	9.4	12.1	1.03	1.13	1.13	1.24	0.47	0.52	0.38	0.42	1.61	1.78	2.26	2.49	2.50	2.76	3.14	3.46
J93	9.3	12.0	1.01	1.12	1.12	1.23	0.47	0.51	0.38	0.41	1.59	1.76	2.23	2.46	2.47	2.73	3.10	3.43
J92	9.2	11.8	1.00	1.11	1.10	1.22	0.46	0.51	0.37	0.41	1.57	1.74	2.21	2.44	2.45	2.70	3.07	3.39
J90	9.0	11.6	0.98	1.08	1.08	1.19	0.45	0.50	0.36	0.40	1.54	1.70	2.16	2.38	2.39	2.64	3.00	3.31
J89	8.9	11.4	0.97	1.07	1.06	1.18	0.44	0.49	0.36	0.40	1.52	1.68	2.12	2.36	2.36	2.61	2.95	3.28
J88	8.8	11.3	0.95	1.06	1.05	1.16	0.44	0.49	0.35	0.39	1.49	1.66	2.09	2.33	2.32	2.58	2.91	3.24
J86	8.6	11.1	0.92	1.03	1.01	1.14	0.42	0.48	0.34	0.38	1.45	1.62	2.03	2.28	2.25	2.52	2.82	3.16
J84	8.4	10.8	0.89	1.01	0.98	1.11	0.41	0.46	0.33	0.37	1.40	1.59	1.96	2.22	2.18	2.46	2.73	3.09
J81	8.1	10.4	0.85	0.97	0.93	1.07	0.39	0.45	0.31	0.36	1.33	1.53	1.86	2.14	2.07	2.38	2.59	2.98
J80	8.0	10.3	0.83	0.96	0.92	1.06	0.38	0.44	0.31	0.36	1.31	1.51	1.83	2.12	2.03	2.35	2.55	2.94
J78	7.8	10.0	0.80	0.94	0.88	1.03	0.37	0.43	0.30	0.35	1.26	1.47	1.77	2.06	1.96	2.29	2.46	2.87
J73	7.3	9.4	0.73	0.88	0.80	0.96	0.34	0.40	0.27	0.32	1.14	1.38	1.60	1.93	1.78	2.14	2.23	2.68
J72	7.2	9.3	0.71	0.86	0.79	0.95	0.33	0.40	0.26	0.32	1.12	1.36	1.57	1.90	1.74	2.11	2.19	2.64
J71	7.1	9.1	0.70	0.85	0.77	0.94	0.32	0.39	0.26	0.32	1.10	1.34	1.54	1.87	1.71	2.08	2.14	2.61

製品仕様

4) YCSJ180MX (7.5HPマルチ) 標準能力表

運転条件：JIS B 8616条件

室内 ユニット 容量 合計	合計能力 kW		ガス消費量 (m³N/h)															
			13A		12A		LPG		ブタン		6A		L1 (6B, 6C)		L2 (5A, 5B) 5C, L1 (7C)		L3 (4A, 4B, 4C)	
	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房
J234	19.3	24.1	1.88	1.70	2.07	1.87	0.86	0.78	0.70	0.63	2.95	2.67	4.14	3.74	4.59	4.15	5.75	5.20
J233	19.3	24.1	1.88	1.70	2.07	1.87	0.86	0.78	0.70	0.63	2.95	2.67	4.13	3.75	4.58	4.15	5.75	5.21
J232	19.3	24.1	1.88	1.71	2.06	1.88	0.86	0.78	0.69	0.63	2.95	2.68	4.13	3.75	4.58	4.16	5.74	5.22
J231	19.2	24.1	1.88	1.71	2.06	1.88	0.86	0.79	0.69	0.63	2.94	2.68	4.13	3.76	4.58	4.17	5.74	5.23
J230	19.2	24.1	1.87	1.71	2.06	1.88	0.86	0.79	0.69	0.63	2.94	2.69	4.12	3.77	4.57	4.18	5.73	5.24
J229	19.2	24.1	1.87	1.71	2.06	1.89	0.86	0.79	0.69	0.63	2.94	2.69	4.12	3.77	4.57	4.18	5.73	5.25
J228	19.2	24.0	1.87	1.72	2.06	1.89	0.86	0.79	0.69	0.64	2.94	2.70	4.12	3.78	4.57	4.19	5.73	5.25
J227	19.1	24.0	1.87	1.72	2.06	1.89	0.86	0.79	0.69	0.64	2.94	2.70	4.11	3.78	4.56	4.20	5.72	5.26
J226	19.1	24.0	1.87	1.72	2.05	1.90	0.86	0.79	0.69	0.64	2.93	2.70	4.11	3.79	4.56	4.20	5.72	5.27
J225	19.1	24.0	1.87	1.73	2.05	1.90	0.86	0.79	0.69	0.64	2.93	2.71	4.11	3.80	4.55	4.21	5.71	5.28
J224	19.1	24.0	1.87	1.73	2.05	1.90	0.86	0.80	0.69	0.64	2.93	2.71	4.10	3.80	4.55	4.22	5.71	5.29
J223	19.0	24.0	1.86	1.73	2.05	1.90	0.86	0.80	0.69	0.64	2.93	2.72	4.10	3.81	4.55	4.22	5.70	5.30
J222	19.0	24.0	1.86	1.73	2.05	1.91	0.86	0.80	0.69	0.64	2.92	2.72	4.10	3.82	4.54	4.23	5.70	5.31
J221	19.0	24.0	1.86	1.74	2.05	1.91	0.86	0.80	0.69	0.64	2.92	2.73	4.09	3.82	4.54	4.24	5.69	5.32
J220	19.0	24.0	1.86	1.74	2.05	1.91	0.86	0.80	0.69	0.64	2.92	2.73	4.09	3.83	4.54	4.25	5.69	5.32
J219	18.9	24.0	1.86	1.74	2.04	1.92	0.85	0.80	0.69	0.64	2.92	2.74	4.09	3.83	4.53	4.25	5.68	5.33
J218	18.9	24.0	1.86	1.75	2.04	1.92	0.85	0.80	0.69	0.65	2.91	2.74	4.08	3.84	4.53	4.26	5.68	5.34
J217	18.9	23.9	1.85	1.75	2.04	1.92	0.85	0.80	0.69	0.65	2.91	2.75	4.08	3.85	4.53	4.27	5.68	5.35
J216	18.9	23.9	1.85	1.75	2.04	1.93	0.85	0.81	0.69	0.65	2.91	2.75	4.08	3.85	4.52	4.27	5.67	5.36
J215	18.8	23.9	1.85	1.75	2.04	1.93	0.85	0.81	0.69	0.65	2.91	2.75	4.07	3.86	4.52	4.28	5.67	5.37
J214	18.8	23.9	1.85	1.76	2.04	1.93	0.85	0.81	0.68	0.65	2.91	2.76	4.07	3.87	4.51	4.29	5.66	5.38
J213	18.8	23.9	1.85	1.76	2.03	1.94	0.85	0.81	0.68	0.65	2.90	2.76	4.07	3.87	4.51	4.29	5.66	5.39
J212	18.8	23.9	1.85	1.76	2.03	1.94	0.85	0.81	0.68	0.65	2.90	2.77	4.06	3.88	4.51	4.30	5.65	5.39
J211	18.7	23.9	1.85	1.77	2.03	1.94	0.85	0.81	0.68	0.65	2.90	2.77	4.06	3.88	4.50	4.31	5.65	5.40
J210	18.7	23.9	1.84	1.77	2.03	1.95	0.85	0.81	0.68	0.65	2.90	2.78	4.06	3.89	4.50	4.32	5.64	5.41
J209	18.7	23.9	1.84	1.77	2.03	1.95	0.85	0.81	0.68	0.66	2.89	2.78	4.05	3.90	4.50	4.32	5.64	5.42
J208	18.7	23.9	1.84	1.77	2.03	1.95	0.85	0.82	0.68	0.66	2.89	2.79	4.05	3.90	4.49	4.33	5.63	5.43
J207	18.7	23.9	1.84	1.78	2.02	1.95	0.85	0.82	0.68	0.66	2.89	2.79	4.05	3.91	4.49	4.34	5.63	5.44
J206	18.6	23.8	1.84	1.78	2.02	1.96	0.85	0.82	0.68	0.66	2.89	2.79	4.04	3.92	4.49	4.34	5.63	5.45
J205	18.6	23.8	1.84	1.78	2.02	1.96	0.85	0.82	0.68	0.66	2.88	2.80	4.04	3.92	4.48	4.35	5.62	5.46
J204	18.6	23.8	1.84	1.79	2.02	1.96	0.84	0.82	0.68	0.66	2.88	2.80	4.04	3.93	4.48	4.36	5.62	5.46
J203	18.6	23.8	1.83	1.79	2.02	1.97	0.84	0.82	0.68	0.66	2.88	2.81	4.03	3.93	4.48	4.36	5.61	5.47
J202	18.5	23.8	1.83	1.79	2.02	1.97	0.84	0.82	0.68	0.66	2.88	2.81	4.03	3.94	4.47	4.37	5.61	5.48
J201	18.5	23.8	1.83	1.79	2.01	1.97	0.84	0.83	0.68	0.66	2.87	2.82	4.03	3.95	4.47	4.38	5.60	5.49
J200	18.5	23.8	1.83	1.80	2.01	1.98	0.84	0.83	0.68	0.66	2.87	2.82	4.03	3.95	4.46	4.39	5.60	5.50
J199	18.5	23.8	1.83	1.80	2.01	1.98	0.84	0.83	0.68	0.67	2.87	2.83	4.02	3.96	4.46	4.39	5.59	5.51
J198	18.4	23.8	1.83	1.80	2.01	1.98	0.84	0.83	0.68	0.67	2.87	2.83	4.02	3.97	4.46	4.40	5.59	5.52
J197	18.4	23.8	1.83	1.81	2.01	1.99	0.84	0.83	0.68	0.67	2.87	2.83	4.02	3.97	4.45	4.41	5.59	5.53
J196	18.4	23.7	1.82	1.81	2.01	1.99	0.84	0.83	0.67	0.67	2.86	2.84	4.01	3.98	4.45	4.41	5.58	5.53
J195	18.4	23.7	1.82	1.81	2.00	1.99	0.84	0.83	0.67	0.67	2.86	2.84	4.01	3.99	4.45	4.42	5.58	5.54
J194	18.3	23.7	1.82	1.81	2.00	1.99	0.84	0.83	0.67	0.67	2.86	2.84	4.01	3.98	4.44	4.41	5.57	5.54
J193	18.3	23.7	1.82	1.81	2.00	1.99	0.84	0.83	0.67	0.67	2.86	2.84	4.00	3.98	4.44	4.41	5.57	5.53
J192	18.3	23.7	1.82	1.81	2.00	1.99	0.84	0.83	0.67	0.67	2.85	2.84	4.00	3.98	4.44	4.41	5.56	5.53
J191	18.3	23.7	1.82	1.81	2.00	1.99	0.84	0.83	0.67	0.67	2.85	2.84	4.00	3.98	4.43	4.41	5.56	5.53
J190	18.2	23.7	1.81	1.81	2.00	1.99	0.83	0.83	0.67	0.67	2.85	2.84	3.99	3.97	4.43	4.41	5.55	5.53
J189	18.2	23.7	1.81	1.81	1.99	1.99	0.83	0.83	0.67	0.67	2.85	2.84	3.99	3.97	4.42	4.41	5.55	5.53
J188	18.2	23.7	1.81	1.81	1.99	1.99	0.83	0.83	0.67	0.67	2.84	2.83	3.99	3.97	4.42	4.40	5.54	5.52

室内 ユニット 容量 合計	合計能力 kW		ガス消費量(m³N/h)															
			13A		12A		LPG		ボタン		6A		L1 (6B, 6C)		L2 (5A, 5B) 5C, L1 (7C)		L3 (4A, 4B, 4C)	
	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房
J187	18.2	23.7	1.81	1.80	1.99	1.98	0.83	0.83	0.67	0.67	2.84	2.83	3.98	3.97	4.42	4.40	5.54	5.52
J186	18.1	23.7	1.81	1.80	1.99	1.98	0.83	0.83	0.67	0.67	2.84	2.83	3.98	3.97	4.41	4.40	5.54	5.52
J185	18.1	23.6	1.81	1.80	1.99	1.98	0.83	0.83	0.67	0.67	2.84	2.83	3.98	3.97	4.41	4.40	5.53	5.52
J184	18.1	23.6	1.81	1.80	1.99	1.98	0.83	0.83	0.67	0.67	2.84	2.83	3.97	3.97	4.41	4.40	5.53	5.52
J183	18.1	23.6	1.80	1.80	1.98	1.98	0.83	0.83	0.67	0.67	2.83	2.83	3.97	3.96	4.40	4.40	5.52	5.51
J182	18.0	23.6	1.80	1.80	1.98	1.98	0.83	0.83	0.67	0.67	2.83	2.83	3.97	3.96	4.40	4.40	5.52	5.51
J181	18.0	23.6	1.80	1.80	1.98	1.98	0.83	0.83	0.67	0.67	2.83	2.83	3.96	3.96	4.40	4.39	5.51	5.51
J180	18.0	23.6	1.80	1.80	1.98	1.98	0.83	0.83	0.67	0.67	2.83	2.83	3.96	3.96	4.39	4.39	5.51	5.51
J179	17.9	23.5	1.79	1.79	1.97	1.97	0.82	0.82	0.66	0.66	2.81	2.81	3.94	3.94	4.37	4.37	5.48	5.48
J178	17.8	23.3	1.78	1.78	1.96	1.96	0.82	0.82	0.66	0.66	2.79	2.79	3.91	3.92	4.34	4.34	5.45	5.45
J177	17.7	23.2	1.77	1.77	1.95	1.95	0.81	0.81	0.65	0.65	2.78	2.78	3.89	3.89	4.32	4.32	5.41	5.42
J176	17.6	23.1	1.76	1.76	1.93	1.94	0.81	0.81	0.65	0.65	2.76	2.76	3.87	3.87	4.29	4.29	5.38	5.39
J175	17.5	22.9	1.75	1.75	1.92	1.93	0.80	0.81	0.65	0.65	2.75	2.75	3.85	3.85	4.27	4.27	5.35	5.36
J174	17.4	22.8	1.74	1.74	1.91	1.91	0.80	0.80	0.64	0.64	2.73	2.73	3.82	3.83	4.24	4.25	5.32	5.32
J173	17.3	22.7	1.73	1.73	1.90	1.90	0.79	0.80	0.64	0.64	2.71	2.72	3.80	3.81	4.22	4.22	5.29	5.29
J172	17.2	22.6	1.72	1.72	1.89	1.89	0.79	0.79	0.64	0.64	2.70	2.70	3.78	3.78	4.19	4.20	5.26	5.26
J171	17.1	22.4	1.71	1.71	1.88	1.88	0.79	0.79	0.63	0.63	2.68	2.68	3.76	3.76	4.17	4.17	5.23	5.23
J170	17.0	22.3	1.70	1.70	1.87	1.87	0.78	0.78	0.63	0.63	2.66	2.67	3.73	3.74	4.14	4.15	5.19	5.20
J169	16.9	22.2	1.69	1.69	1.86	1.86	0.78	0.78	0.62	0.63	2.65	2.65	3.71	3.72	4.12	4.12	5.16	5.17
J168	16.8	22.0	1.68	1.68	1.84	1.85	0.77	0.77	0.62	0.62	2.63	2.64	3.69	3.70	4.09	4.10	5.13	5.14
J167	16.7	21.9	1.67	1.67	1.83	1.84	0.77	0.77	0.62	0.62	2.62	2.62	3.67	3.67	4.07	4.07	5.10	5.11
J166	16.6	21.8	1.66	1.66	1.82	1.83	0.76	0.76	0.61	0.61	2.60	2.61	3.64	3.65	4.04	4.05	5.07	5.08
J165	16.5	21.6	1.65	1.65	1.81	1.82	0.76	0.76	0.61	0.61	2.58	2.59	3.62	3.63	4.02	4.03	5.04	5.05
J164	16.4	21.5	1.64	1.64	1.80	1.80	0.75	0.75	0.61	0.61	2.57	2.57	3.60	3.61	3.99	4.00	5.01	5.02
J163	16.3	21.4	1.63	1.63	1.79	1.79	0.75	0.75	0.60	0.60	2.55	2.56	3.58	3.59	3.97	3.98	4.97	4.99
J162	16.2	21.2	1.62	1.62	1.78	1.78	0.74	0.75	0.60	0.60	2.54	2.54	3.55	3.56	3.94	3.95	4.94	4.96
J161	16.1	21.1	1.60	1.61	1.77	1.77	0.74	0.74	0.59	0.60	2.52	2.53	3.53	3.54	3.92	3.93	4.91	4.93
J160	16.0	21.0	1.59	1.60	1.75	1.76	0.73	0.74	0.59	0.59	2.50	2.51	3.51	3.52	3.89	3.90	4.88	4.90
J159	15.9	20.8	1.58	1.59	1.74	1.75	0.73	0.73	0.59	0.59	2.49	2.50	3.49	3.50	3.87	3.88	4.85	4.87
J158	15.8	20.7	1.57	1.58	1.73	1.74	0.72	0.73	0.58	0.58	2.47	2.48	3.46	3.48	3.84	3.86	4.82	4.83
J157	15.7	20.6	1.56	1.57	1.72	1.73	0.72	0.72	0.58	0.58	2.46	2.46	3.44	3.45	3.82	3.83	4.79	4.80
J156	15.6	20.5	1.55	1.56	1.71	1.72	0.71	0.72	0.57	0.58	2.44	2.45	3.42	3.43	3.79	3.81	4.75	4.77
J155	15.5	20.3	1.54	1.55	1.70	1.71	0.71	0.71	0.57	0.57	2.42	2.43	3.40	3.41	3.77	3.78	4.72	4.74
J154	15.4	20.2	1.53	1.54	1.69	1.69	0.71	0.71	0.57	0.57	2.41	2.42	3.37	3.39	3.74	3.76	4.69	4.71
J153	15.3	20.1	1.52	1.53	1.68	1.68	0.70	0.70	0.56	0.57	2.39	2.40	3.35	3.37	3.72	3.73	4.66	4.68
J152	15.2	19.9	1.51	1.52	1.66	1.67	0.70	0.70	0.56	0.56	2.37	2.39	3.33	3.34	3.69	3.71	4.63	4.65
J151	15.1	19.8	1.50	1.51	1.65	1.66	0.69	0.69	0.56	0.56	2.36	2.37	3.31	3.32	3.67	3.68	4.60	4.62
J150	15.0	19.7	1.49	1.50	1.64	1.65	0.69	0.69	0.55	0.56	2.34	2.36	3.28	3.30	3.64	3.66	4.57	4.59
J149	14.9	19.5	1.48	1.49	1.63	1.64	0.68	0.69	0.55	0.55	2.33	2.34	3.26	3.28	3.62	3.64	4.53	4.56
J148	14.8	19.4	1.47	1.48	1.62	1.63	0.68	0.68	0.54	0.55	2.31	2.32	3.24	3.26	3.59	3.61	4.50	4.53
J147	14.7	19.3	1.46	1.47	1.61	1.62	0.67	0.68	0.54	0.54	2.29	2.31	3.21	3.23	3.57	3.59	4.47	4.50
J146	14.6	19.1	1.45	1.46	1.60	1.61	0.67	0.67	0.54	0.54	2.28	2.29	3.19	3.21	3.54	3.56	4.44	4.47
J145	14.5	19.0	1.44	1.45	1.58	1.60	0.66	0.67	0.53	0.54	2.26	2.28	3.17	3.19	3.52	3.54	4.41	4.44
J144	14.4	18.9	1.43	1.44	1.57	1.58	0.66	0.66	0.53	0.53	2.25	2.26	3.15	3.17	3.49	3.51	4.38	4.41
J143	14.3	18.7	1.42	1.43	1.56	1.57	0.65	0.66	0.53	0.53	2.23	2.25	3.12	3.15	3.47	3.49	4.35	4.38
J142	14.2	18.6	1.41	1.42	1.55	1.56	0.65	0.65	0.52	0.53	2.21	2.23	3.10	3.12	3.44	3.46	4.31	4.35
J140	14.0	18.4	1.39	1.40	1.53	1.54	0.64	0.64	0.51	0.52	2.18	2.20	3.06	3.08	3.39	3.42	4.25	4.28

製品仕様

室内 ユニット 容量 合計	合計能力 kW		ガス消費量 (m³N/h)															
			13A		12A		LPG		ボタン		6A		L1 (6B, 6C)		L2 (5A, 5B) 5C, L1 (7C)		L3 (4A, 4B, 4C)	
	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房
J139	13.9	18.2	1.38	1.39	1.52	1.53	0.63	0.64	0.51	0.51	2.17	2.18	3.03	3.06	3.37	3.39	4.22	4.25
J138	13.8	18.1	1.37	1.38	1.51	1.52	0.63	0.63	0.51	0.51	2.15	2.17	3.01	3.04	3.34	3.37	4.19	4.22
J137	13.7	18.0	1.36	1.37	1.49	1.51	0.62	0.63	0.50	0.51	2.13	2.15	2.99	3.01	3.32	3.34	4.16	4.19
J136	13.6	17.8	1.35	1.36	1.48	1.50	0.62	0.63	0.50	0.50	2.12	2.14	2.97	2.99	3.29	3.32	4.13	4.16
J135	13.5	17.7	1.34	1.35	1.47	1.49	0.62	0.62	0.50	0.50	2.10	2.12	2.94	2.97	3.26	3.29	4.09	4.13
J134	13.4	17.6	1.33	1.34	1.46	1.47	0.61	0.62	0.49	0.50	2.08	2.10	2.92	2.95	3.24	3.27	4.06	4.10
J133	13.3	17.4	1.32	1.33	1.45	1.46	0.61	0.61	0.49	0.49	2.07	2.09	2.90	2.93	3.21	3.25	4.03	4.07
J132	13.2	17.3	1.31	1.32	1.44	1.45	0.60	0.61	0.48	0.49	2.05	2.07	2.88	2.90	3.19	3.22	4.00	4.04
J131	13.1	17.2	1.30	1.31	1.43	1.44	0.60	0.60	0.48	0.48	2.04	2.06	2.85	2.88	3.16	3.20	3.97	4.01
J130	13.0	17.0	1.29	1.30	1.42	1.43	0.59	0.60	0.48	0.48	2.02	2.04	2.83	2.86	3.14	3.17	3.94	3.98
J129	12.9	16.9	1.28	1.29	1.40	1.42	0.59	0.59	0.47	0.48	2.00	2.03	2.81	2.84	3.11	3.15	3.91	3.95
J128	12.8	16.8	1.27	1.28	1.39	1.41	0.58	0.59	0.47	0.47	1.99	2.01	2.79	2.82	3.09	3.12	3.87	3.92
J127	12.7	16.7	1.26	1.27	1.38	1.40	0.58	0.58	0.46	0.47	1.97	1.99	2.76	2.79	3.06	3.10	3.84	3.89
J126	12.6	16.5	1.25	1.26	1.37	1.39	0.57	0.58	0.46	0.47	1.96	1.98	2.74	2.77	3.04	3.07	3.81	3.86
J125	12.5	16.4	1.24	1.25	1.36	1.38	0.57	0.58	0.46	0.46	1.94	1.96	2.72	2.75	3.01	3.05	3.78	3.83
J124	12.4	16.3	1.23	1.24	1.35	1.36	0.56	0.57	0.45	0.46	1.92	1.95	2.70	2.73	2.99	3.03	3.75	3.79
J123	12.3	16.1	1.21	1.23	1.34	1.35	0.56	0.57	0.45	0.46	1.91	1.93	2.67	2.71	2.96	3.00	3.72	3.76
J122	12.2	16.0	1.20	1.22	1.33	1.34	0.55	0.56	0.45	0.45	1.89	1.92	2.65	2.68	2.94	2.98	3.69	3.73
J121	12.1	15.9	1.19	1.21	1.31	1.33	0.55	0.56	0.44	0.45	1.88	1.90	2.63	2.66	2.91	2.95	3.65	3.70
J120	12.0	15.7	1.18	1.20	1.30	1.32	0.54	0.55	0.44	0.44	1.86	1.88	2.61	2.64	2.89	2.93	3.62	3.67
J118	11.8	15.5	1.16	1.18	1.28	1.30	0.54	0.54	0.43	0.44	1.83	1.85	2.56	2.60	2.84	2.88	3.56	3.61
J117	11.7	15.3	1.15	1.17	1.27	1.29	0.53	0.54	0.43	0.43	1.81	1.84	2.54	2.57	2.81	2.85	3.53	3.58
J116	11.6	15.2	1.14	1.16	1.26	1.28	0.53	0.53	0.42	0.43	1.79	1.82	2.51	2.55	2.79	2.83	3.50	3.55
J115	11.5	15.1	1.13	1.15	1.24	1.27	0.52	0.53	0.42	0.43	1.77	1.81	2.49	2.53	2.76	2.81	3.46	3.52
J114	11.4	14.9	1.12	1.14	1.23	1.25	0.51	0.52	0.41	0.42	1.75	1.79	2.46	2.51	2.73	2.78	3.42	3.49
J112	11.2	14.7	1.09	1.12	1.20	1.23	0.50	0.52	0.40	0.41	1.71	1.76	2.40	2.46	2.66	2.73	3.33	3.43
J111	11.1	14.6	1.08	1.11	1.18	1.22	0.49	0.51	0.40	0.41	1.69	1.74	2.37	2.44	2.63	2.71	3.29	3.40
J110	11.0	14.4	1.06	1.10	1.17	1.21	0.49	0.51	0.39	0.41	1.67	1.73	2.34	2.42	2.59	2.68	3.25	3.37
J109	10.9	14.3	1.05	1.09	1.15	1.20	0.48	0.50	0.39	0.40	1.65	1.71	2.31	2.40	2.56	2.66	3.21	3.34
J108	10.8	14.2	1.04	1.08	1.14	1.19	0.48	0.50	0.38	0.40	1.63	1.70	2.28	2.38	2.53	2.64	3.17	3.30
J107	10.7	14.0	1.02	1.07	1.12	1.18	0.47	0.49	0.38	0.40	1.60	1.68	2.25	2.35	2.49	2.61	3.13	3.27
J106	10.6	13.9	1.01	1.06	1.11	1.17	0.46	0.49	0.37	0.39	1.58	1.66	2.22	2.33	2.46	2.59	3.08	3.24
J103	10.3	13.5	0.97	1.03	1.06	1.13	0.44	0.47	0.36	0.38	1.52	1.62	2.13	2.27	2.36	2.51	2.96	3.15
J102	10.2	13.4	0.95	1.02	1.05	1.12	0.44	0.47	0.35	0.38	1.50	1.60	2.10	2.24	2.33	2.49	2.92	3.12
J101	10.1	13.2	0.94	1.01	1.03	1.11	0.43	0.46	0.35	0.37	1.48	1.59	2.07	2.22	2.29	2.46	2.88	3.09
J100	10.0	13.1	0.93	1.00	1.02	1.10	0.43	0.46	0.34	0.37	1.45	1.57	2.04	2.20	2.26	2.44	2.83	3.06
J99	9.9	13.0	0.91	0.99	1.00	1.09	0.42	0.46	0.34	0.37	1.43	1.55	2.01	2.18	2.23	2.42	2.79	3.03
J95	9.5	12.5	0.86	0.95	0.94	1.05	0.39	0.44	0.32	0.35	1.35	1.49	1.89	2.09	2.09	2.32	2.63	2.91
J94	9.4	12.3	0.84	0.94	0.93	1.03	0.39	0.43	0.31	0.35	1.33	1.48	1.86	2.07	2.06	2.29	2.58	2.88
J93	9.3	12.2	0.83	0.93	0.91	1.02	0.38	0.43	0.31	0.34	1.30	1.46	1.83	2.05	2.03	2.27	2.54	2.85
J92	9.2	12.1	0.82	0.92	0.90	1.01	0.38	0.42	0.30	0.34	1.28	1.44	1.80	2.02	1.99	2.24	2.50	2.82
J90	9.0	11.8	0.79	0.90	0.87	0.99	0.36	0.41	0.29	0.33	1.24	1.41	1.74	1.98	1.93	2.20	2.42	2.75