

製品仕様

3) YCSJ140MX (5Pマルチ) 標準能力表

運転条件：JIS B 8616条件

室内 ユニット 容量 合計	合計能力 kW		ガス消費量 (m³N/h)															
			13A		12A		LPG		ブタン		6A		L1 (6B, 6C)		L2 (5A, 5B) 5C, L1 (7C)		L3 (4A, 4B, 4C)	
	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房
J182	14.9	18.4	1.63	1.59	1.79	1.75	0.75	0.73	0.60	0.59	2.55	2.50	3.58	3.50	3.97	3.89	4.97	4.87
J181	14.9	18.4	1.62	1.60	1.79	1.76	0.75	0.73	0.60	0.59	2.55	2.51	3.57	3.51	3.96	3.90	4.97	4.89
J180	14.9	18.4	1.62	1.60	1.78	1.76	0.75	0.74	0.60	0.59	2.55	2.51	3.57	3.52	3.96	3.90	4.96	4.90
J179	14.8	18.4	1.62	1.60	1.78	1.76	0.75	0.74	0.60	0.59	2.54	2.52	3.56	3.53	3.95	3.91	4.96	4.91
J178	14.8	18.4	1.62	1.61	1.78	1.77	0.74	0.74	0.60	0.59	2.54	2.52	3.56	3.54	3.95	3.92	4.95	4.92
J177	14.8	18.4	1.62	1.61	1.78	1.77	0.74	0.74	0.60	0.60	2.54	2.53	3.56	3.54	3.94	3.93	4.95	4.93
J176	14.8	18.3	1.61	1.61	1.78	1.78	0.74	0.74	0.60	0.60	2.53	2.53	3.55	3.55	3.94	3.94	4.94	4.94
J175	14.8	18.3	1.61	1.62	1.77	1.78	0.74	0.74	0.60	0.60	2.53	2.54	3.55	3.56	3.93	3.95	4.93	4.95
J174	14.7	18.3	1.61	1.62	1.77	1.78	0.74	0.75	0.60	0.60	2.53	2.55	3.54	3.57	3.93	3.96	4.93	4.96
J173	14.7	18.3	1.61	1.63	1.77	1.79	0.74	0.75	0.60	0.60	2.53	2.55	3.54	3.58	3.93	3.97	4.92	4.97
J172	14.7	18.3	1.61	1.63	1.77	1.79	0.74	0.75	0.59	0.60	2.52	2.56	3.54	3.58	3.92	3.97	4.92	4.98
J171	14.7	18.3	1.61	1.63	1.77	1.80	0.74	0.75	0.59	0.60	2.52	2.56	3.53	3.59	3.92	3.98	4.91	4.99
J170	14.6	18.3	1.60	1.64	1.76	1.80	0.74	0.75	0.59	0.61	2.52	2.57	3.53	3.60	3.91	3.99	4.91	5.01
J169	14.6	18.3	1.60	1.64	1.76	1.80	0.74	0.75	0.59	0.61	2.51	2.57	3.52	3.61	3.91	4.00	4.90	5.02
J168	14.6	18.3	1.60	1.64	1.76	1.81	0.74	0.76	0.59	0.61	2.51	2.58	3.52	3.61	3.90	4.01	4.90	5.03
J167	14.6	18.3	1.60	1.65	1.76	1.81	0.74	0.76	0.59	0.61	2.51	2.58	3.52	3.62	3.90	4.02	4.89	5.04
J166	14.6	18.2	1.60	1.65	1.76	1.82	0.73	0.76	0.59	0.61	2.51	2.59	3.51	3.63	3.90	4.03	4.89	5.05
J165	14.5	18.2	1.59	1.65	1.75	1.82	0.73	0.76	0.59	0.61	2.50	2.60	3.51	3.64	3.89	4.03	4.88	5.06
J164	14.5	18.2	1.59	1.66	1.75	1.82	0.73	0.76	0.59	0.61	2.50	2.60	3.50	3.65	3.89	4.04	4.87	5.07
J163	14.5	18.2	1.59	1.66	1.75	1.83	0.73	0.76	0.59	0.61	2.50	2.61	3.50	3.65	3.88	4.05	4.87	5.08
J162	14.5	18.2	1.59	1.66	1.75	1.83	0.73	0.77	0.59	0.62	2.50	2.61	3.50	3.66	3.88	4.06	4.86	5.09
J161	14.5	18.2	1.59	1.67	1.75	1.83	0.73	0.77	0.59	0.62	2.49	2.62	3.49	3.67	3.87	4.07	4.86	5.10
J160	14.4	18.2	1.59	1.67	1.74	1.84	0.73	0.77	0.59	0.62	2.49	2.62	3.49	3.68	3.87	4.08	4.85	5.11
J159	14.4	18.2	1.58	1.68	1.74	1.84	0.73	0.77	0.59	0.62	2.49	2.63	3.48	3.69	3.86	4.09	4.85	5.13
J158	14.4	18.2	1.58	1.68	1.74	1.85	0.73	0.77	0.59	0.62	2.48	2.64	3.48	3.69	3.86	4.10	4.84	5.14
J157	14.4	18.2	1.58	1.68	1.74	1.85	0.73	0.77	0.58	0.62	2.48	2.64	3.48	3.70	3.86	4.10	4.84	5.15
J156	14.3	18.2	1.58	1.69	1.74	1.85	0.73	0.78	0.58	0.62	2.48	2.65	3.47	3.71	3.85	4.11	4.83	5.16
J155	14.3	18.1	1.58	1.69	1.73	1.86	0.73	0.78	0.58	0.63	2.48	2.65	3.47	3.72	3.85	4.12	4.82	5.17
J154	14.3	18.1	1.58	1.69	1.73	1.86	0.72	0.78	0.58	0.63	2.47	2.66	3.47	3.72	3.84	4.13	4.82	5.18
J153	14.3	18.1	1.57	1.70	1.73	1.87	0.72	0.78	0.58	0.63	2.47	2.66	3.46	3.73	3.84	4.14	4.81	5.19
J152	14.3	18.1	1.57	1.70	1.73	1.87	0.72	0.78	0.58	0.63	2.47	2.67	3.46	3.74	3.83	4.15	4.81	5.20
J151	14.2	18.1	1.57	1.70	1.73	1.87	0.72	0.78	0.58	0.63	2.46	2.67	3.45	3.74	3.83	4.15	4.80	5.20
J150	14.2	18.1	1.57	1.70	1.72	1.87	0.72	0.78	0.58	0.63	2.46	2.67	3.45	3.73	3.82	4.14	4.80	5.20
J149	14.2	18.1	1.57	1.70	1.72	1.87	0.72	0.78	0.58	0.63	2.46	2.67	3.45	3.73	3.82	4.14	4.79	5.19
J148	14.2	18.1	1.56	1.70	1.72	1.87	0.72	0.78	0.58	0.63	2.46	2.66	3.44	3.73	3.82	4.14	4.79	5.19
J147	14.2	18.1	1.56	1.70	1.72	1.87	0.72	0.78	0.58	0.63	2.45	2.66	3.44	3.73	3.81	4.14	4.78	5.19
J146	14.1	18.1	1.56	1.70	1.72	1.86	0.72	0.78	0.58	0.63	2.45	2.66	3.43	3.73	3.81	4.14	4.78	5.19
J145	14.1	18.0	1.56	1.69	1.71	1.86	0.72	0.78	0.58	0.63	2.45	2.66	3.43	3.73	3.80	4.13	4.77	5.18
J144	14.1	18.0	1.56	1.69	1.71	1.86	0.72	0.78	0.58	0.63	2.44	2.66	3.43	3.73	3.80	4.13	4.76	5.18
J143	14.1	18.0	1.56	1.69	1.71	1.86	0.72	0.78	0.58	0.63	2.44	2.66	3.42	3.72	3.80	4.13	4.76	5.18
J142	14.0	18.0	1.55	1.69	1.71	1.86	0.71	0.78	0.57	0.63	2.44	2.66	3.42	3.72	3.79	4.13	4.75	5.18
J140	14.0	18.0	1.55	1.69	1.71	1.86	0.71	0.78	0.57	0.63	2.43	2.65	3.41	3.72	3.78	4.12	4.74	5.17
J139	13.9	17.9	1.54	1.68	1.69	1.85	0.71	0.77	0.57	0.62	2.42	2.63	3.38	3.69	3.75	4.09	4.71	5.13
J138	13.8	17.7	1.53	1.67	1.68	1.83	0.70	0.77	0.57	0.62	2.40	2.62	3.36	3.66	3.73	4.06	4.67	5.10
J137	13.7	17.6	1.52	1.65	1.67	1.82	0.70	0.76	0.56	0.61	2.38	2.60	3.33	3.64	3.70	4.03	4.64	5.06
J136	13.6	17.5	1.50	1.64	1.65	1.81	0.69	0.76	0.56	0.61	2.36	2.58	3.31	3.61	3.67	4.01	4.60	5.02
J135	13.5	17.4	1.49	1.63	1.64	1.79	0.69	0.75	0.55	0.60	2.34	2.56	3.28	3.58	3.64	3.98	4.57	4.99

室内 ユニット 容量 合計	合計能力 kW		ガス消費量(m³N/h)															
			13A		12A		LPG		ボタン		6A		L1 (6B, 6C)		L2 (5A, 5B) 5C, L1 (7C)		L3 (4A, 4B, 4C)	
	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房	冷房	暖房
J134	13.4	17.2	1.48	1.62	1.63	1.78	0.68	0.74	0.55	0.60	2.33	2.54	3.26	3.56	3.62	3.95	4.53	4.95
J133	13.3	17.1	1.47	1.61	1.62	1.77	0.68	0.74	0.54	0.59	2.31	2.52	3.23	3.53	3.59	3.92	4.50	4.91
J132	13.2	17.0	1.46	1.59	1.60	1.75	0.67	0.73	0.54	0.59	2.29	2.50	3.21	3.50	3.56	3.89	4.46	4.87
J131	13.1	16.8	1.45	1.58	1.59	1.74	0.67	0.73	0.54	0.58	2.27	2.48	3.18	3.48	3.53	3.86	4.43	4.84
J130	13.0	16.7	1.44	1.57	1.58	1.73	0.66	0.72	0.53	0.58	2.25	2.46	3.16	3.45	3.50	3.83	4.39	4.80
J129	12.9	16.6	1.42	1.56	1.57	1.71	0.66	0.72	0.53	0.58	2.24	2.44	3.13	3.42	3.48	3.80	4.36	4.76
J128	12.8	16.5	1.41	1.54	1.55	1.70	0.65	0.71	0.52	0.57	2.22	2.42	3.11	3.40	3.45	3.77	4.32	4.73
J127	12.7	16.3	1.40	1.53	1.54	1.69	0.64	0.70	0.52	0.57	2.20	2.41	3.08	3.37	3.42	3.74	4.29	4.69
J126	12.6	16.2	1.39	1.52	1.53	1.67	0.64	0.70	0.51	0.56	2.18	2.39	3.06	3.34	3.39	3.71	4.25	4.65
J125	12.5	16.1	1.38	1.51	1.52	1.66	0.63	0.69	0.51	0.56	2.17	2.37	3.03	3.32	3.36	3.68	4.22	4.61
J124	12.4	15.9	1.37	1.50	1.50	1.65	0.63	0.69	0.51	0.55	2.15	2.35	3.01	3.29	3.34	3.65	4.18	4.58
J123	12.3	15.8	1.36	1.48	1.49	1.63	0.62	0.68	0.50	0.55	2.13	2.33	2.98	3.26	3.31	3.62	4.15	4.54
J122	12.2	15.7	1.34	1.47	1.48	1.62	0.62	0.68	0.50	0.54	2.11	2.31	2.96	3.24	3.28	3.59	4.12	4.50
J121	12.1	15.6	1.33	1.46	1.47	1.61	0.61	0.67	0.49	0.54	2.09	2.29	2.93	3.21	3.25	3.56	4.08	4.47
J120	12.0	15.4	1.32	1.45	1.45	1.59	0.61	0.67	0.49	0.54	2.08	2.27	2.91	3.18	3.23	3.53	4.05	4.43
J118	11.8	15.2	1.30	1.42	1.43	1.57	0.60	0.65	0.48	0.53	2.04	2.23	2.86	3.13	3.17	3.47	3.98	4.35
J117	11.7	15.0	1.29	1.41	1.42	1.55	0.59	0.65	0.48	0.52	2.02	2.21	2.83	3.10	3.14	3.44	3.94	4.32
J116	11.6	14.9	1.28	1.40	1.40	1.54	0.59	0.64	0.47	0.52	2.00	2.20	2.81	3.08	3.11	3.41	3.91	4.28
J115	11.5	14.8	1.27	1.39	1.39	1.53	0.58	0.64	0.47	0.51	1.99	2.18	2.78	3.05	3.09	3.38	3.87	4.24
J114	11.4	14.7	1.25	1.37	1.38	1.51	0.58	0.63	0.46	0.51	1.97	2.16	2.76	3.02	3.06	3.35	3.84	4.21
J112	11.2	14.4	1.23	1.35	1.35	1.49	0.57	0.62	0.46	0.50	1.93	2.12	2.71	2.97	3.00	3.29	3.77	4.13
J111	11.1	14.3	1.22	1.34	1.34	1.47	0.56	0.62	0.45	0.50	1.91	2.10	2.68	2.94	2.98	3.26	3.73	4.09
J110	11.0	14.1	1.21	1.33	1.33	1.46	0.56	0.61	0.45	0.49	1.90	2.08	2.66	2.92	2.95	3.23	3.70	4.06
J109	10.9	14.0	1.20	1.31	1.32	1.44	0.55	0.60	0.44	0.49	1.88	2.06	2.63	2.89	2.92	3.21	3.66	4.02
J108	10.8	13.9	1.19	1.30	1.30	1.43	0.55	0.60	0.44	0.48	1.86	2.04	2.61	2.86	2.89	3.18	3.63	3.98
J107	10.7	13.8	1.17	1.29	1.29	1.42	0.54	0.59	0.43	0.48	1.84	2.02	2.58	2.84	2.86	3.15	3.59	3.95
J106	10.6	13.6	1.16	1.28	1.28	1.40	0.53	0.59	0.43	0.47	1.82	2.01	2.56	2.81	2.84	3.12	3.56	3.91
J103	10.3	13.2	1.13	1.24	1.24	1.36	0.52	0.57	0.42	0.46	1.77	1.95	2.48	2.73	2.75	3.03	3.45	3.80
J102	10.2	13.1	1.12	1.23	1.23	1.35	0.51	0.57	0.41	0.45	1.75	1.93	2.46	2.70	2.72	3.00	3.42	3.76
J101	10.1	13.0	1.11	1.22	1.22	1.34	0.51	0.56	0.41	0.45	1.74	1.91	2.43	2.68	2.70	2.97	3.38	3.72
J100	10.0	12.9	1.09	1.20	1.20	1.32	0.50	0.55	0.40	0.45	1.72	1.89	2.41	2.65	2.67	2.94	3.35	3.69
J99	9.9	12.7	1.08	1.19	1.19	1.31	0.50	0.55	0.40	0.44	1.70	1.87	2.38	2.62	2.64	2.91	3.31	3.65
J95	9.5	12.2	1.04	1.14	1.14	1.26	0.48	0.53	0.38	0.42	1.63	1.80	2.28	2.52	2.53	2.79	3.17	3.50
J94	9.4	12.1	1.03	1.13	1.13	1.24	0.47	0.52	0.38	0.42	1.61	1.78	2.26	2.49	2.50	2.76	3.14	3.46
J93	9.3	12.0	1.01	1.12	1.12	1.23	0.47	0.51	0.38	0.41	1.59	1.76	2.23	2.46	2.47	2.73	3.10	3.43
J92	9.2	11.8	1.00	1.11	1.10	1.22	0.46	0.51	0.37	0.41	1.57	1.74	2.21	2.44	2.45	2.70	3.07	3.39
J90	9.0	11.6	0.98	1.08	1.08	1.19	0.45	0.50	0.36	0.40	1.54	1.70	2.16	2.38	2.39	2.64	3.00	3.31
J89	8.9	11.4	0.97	1.07	1.06	1.18	0.44	0.49	0.36	0.40	1.52	1.68	2.12	2.36	2.36	2.61	2.95	3.28
J88	8.8	11.3	0.95	1.06	1.05	1.16	0.44	0.49	0.35	0.39	1.49	1.66	2.09	2.33	2.32	2.58	2.91	3.24
J86	8.6	11.1	0.92	1.03	1.01	1.14	0.42	0.48	0.34	0.38	1.45	1.62	2.03	2.28	2.25	2.52	2.82	3.16
J84	8.4	10.8	0.89	1.01	0.98	1.11	0.41	0.46	0.33	0.37	1.40	1.59	1.96	2.22	2.18	2.46	2.73	3.09
J81	8.1	10.4	0.85	0.97	0.93	1.07	0.39	0.45	0.31	0.36	1.33	1.53	1.86	2.14	2.07	2.38	2.59	2.98
J80	8.0	10.3	0.83	0.96	0.92	1.06	0.38	0.44	0.31	0.36	1.31	1.51	1.83	2.12	2.03	2.35	2.55	2.94
J78	7.8	10.0	0.80	0.94	0.88	1.03	0.37	0.43	0.30	0.35	1.26	1.47	1.77	2.06	1.96	2.29	2.46	2.87
J73	7.3	9.4	0.73	0.88	0.80	0.96	0.34	0.40	0.27	0.32	1.14	1.38	1.60	1.93	1.78	2.14	2.23	2.68
J72	7.2	9.3	0.71	0.86	0.79	0.95	0.33	0.40	0.26	0.32	1.12	1.36	1.57	1.90	1.74	2.11	2.19	2.64
J71	7.1	9.1	0.70	0.85	0.77	0.94	0.32	0.39	0.26	0.32	1.10	1.34	1.54	1.87	1.71	2.08	2.14	2.61